



OFFICE OF THE EXECUTIVE ENGINEER, SAMBALPUR (R&B) DIVISION NO- I

No. 5205 /dt. 10/8/21

To

The Principal
PRABHUJI ENGLISH MEDIUM SCHOOL,RAIRAKHOL,SAMBALPUR,ODISHA

Sub: Regarding building safety certificate.

Ref: Letter no.16/PEMS/2021-22 Dt.26-07-2021.

Sir,

In inviting kind a reference to the subject cited above and as per the visual inspection done by A.E.E Rairakhhol on 30.07.2021 it is to state that the above mentioned three storeyed framed structure seems **visually ok and safe** for functioning of school class due to absence of any visual cracks in any structural components as well as no leakage of water from roof slab.

But neither any drawing nor any structural design was available from the school authority in this regard.

Yours faithfully,

Executive Engineer
Sambalpur (R&B) Division -I.

Memo No. /dt.

Copy forwarded to A.E.E , Rairakhhol (R&B) Sub division for information.

Executive Engineer
Sambalpur (R&B) Division -I.